

**Architects Update for Electrical Design 3-31-14**

**Note the following additions to the Electrical design.** Three files have been added to the Electrical Design page.

**Add Panel Schedule "PC1A"**

**Add Panel Schedule "PC2A"**

**For Emergency Panel "EGEMDB" change the rating from 1200amps to 2500amps**

**Add Layout of the Emergency Electrical Room**