

Question:

At the six Bariatric Rooms called for in Addendum 5, are the grab bars at the bathroom required to withstand added loads?

Answer:

Yes, Grab bars at Bariatric room locations must be able to withstand 600# loads as stipulated in the Code. GC to provide added suitable backing at metal stud partitions to allow for this.