

Question from J. Scull Construction 3-31-14

Q: Where the asphalt shingles occur is this plywood, osb, and or dens deck. Please clarify material and thickness.

Architects Answer:

A: As indicated in Detail 1 Sheet A-601, the roof sheeting is 5/8" Fire Retardant treated plywood.